

污水化验2020年月平均报表1



厂名: 六圩厂

月份	COD _{cr} (mg/L)		BOD ₅ (mg/L)		SS (mg/L)		PH		TN (mg/L)		NH ₃ -N (mg/L)		TP (mg/L)	
	进水	出水	进水	出水	进水	出水	进水	出水	进水	出水	进水	出水	进水	出水
1	246	24	106	2.9	127	5	7.73	7.21	34.3	8.83	27.9	0.382	2.95	0.237
2	236	19	104	2.8	126	4	7.69	7.19	31.1	10.1	24.9	0.522	2.86	0.262
3	282	24	115	2.9	131	5	7.71	7.19	31.1	8.82	25.1	0.467	2.94	0.220
4	286	26	114	3.3	150	6	7.75	7.23	33.1	9.55	27.9	0.350	3.37	0.220
5	317	27	122	5.3	152	6	7.83	7.43	34.6	9.94	30.0	0.193	3.80	0.247
6	264	24	106	4.7	127	5	7.83	7.43	30.0	9.47	26.8	0.221	2.94	0.222
7	257	24	105	4.6	132	5	7.87	7.29	27.1	8.56	24.3	0.187	2.65	0.208
8	251	24	98.3	4.2	136	6	7.89	7.27	25.3	7.99	21.7	0.160	2.48	0.213
9	242	23	100	3.5	125	5	7.85	7.22	28.0	8.70	24.6	0.347	2.58	0.187
10	214	17	86.3	3.1	124	5	7.86	7.22	32.3	10.1	27.5	0.386	3.03	0.279
11	228	16	103	3.3	130	4	7.80	7.23	34.9	10.1	29.3	0.428	3.60	0.188
12	248	17	111	3.2	130	6	7.83	7.21	36.6	9.67	31.0	0.419	3.51	0.178
平均值	256	22	106	3.7	133	5	7.80	7.26	31.5	9.32	26.8	0.339	3.06	0.222

编制: 潘咏萍

复核: 顾娟娟

负责: 吴靖